

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Creek Co RWD #7 Did Not Meet Treatment Requirements

Our water system recently violated a drinking water requirement. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct the situation.

#### Creek County RWD # 7 Has Levels of Haloacetic Acids (HAA5) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for haloacetic acids. The standard or MCL for haloacetic acids is 0.060 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of haloacetic acids averaged at our systems location was the following:

Monitoring Location	12 month time period	Location RAA
DBPMX- 13617 W 186	1 <sup>st</sup> Quarter 2025	0.087 mg/L

**What happened? What should I do?** There is nothing you need to do unless you have a severely compromised immune system, have an infant, or elderly, you may be at increased risk and should seek advice from your health care providers about drinking the water.

**What does that mean?** This is not an emergency. If it had been, you would have been notified immediately. *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have increased risk of getting cancer.*

#### CORRECTIVE ACTION

What happened? What is being done? When will the violation be resolved? The results are from a nine (9) month average. Our response will be to increase our coagulant to drop the DBP average over the RAA that we have to use which will be a ¼ average over a 9 month time span.

For more information, please contact: Charles Linnet at 918-827-6575.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example) people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Creek Co RWD #7      PWSID# OK1020405      NOV # P-1020405-25-2

Date Distributed. 05/23/2025